

EFI Global Inc.
5024 Campbell Boulevard, Suite F
White Marsh, MD 21236

Mercury Vapor Assessment Report

Project Location:

Old Cedar Lane School
5451 Beaverkill Rd
Columbia, MD 21044

Prepared For:

Howard County Public School System
10910 Clarksville Pike
Ellicott City, MD 21042

Prepared by:

EFI Global Inc.

EFI Global File No.: 048.04596

August 1, 2024

August 1, 2024

Christopher Madden, CIH
Office of the Environment
Howard County Public School System
10910 Clarksville Pike, Ellicott City, MD 21042

RE: **Mercury Vapor Assessment Report
Old Cedar Lane School
5451 Beverkill Rd, Columbia, MD
EFI Project No. 048.04596**

Dear Mr. Madden,

EFI Global, Inc. (EFI) was retained by HCPSS to conduct mercury vapor testing at the referenced location where a mercury-containing gym floor had been removed. This monitoring was intended to confirm mercury vapor has been sufficiently removed or controlled.

ASSESSMENT METHOD

Mercury Vapor Sampling

EFI conducted air sampling on July 15, 2024, for approximately 8 hours in three locations in the gym. Sampling was conducted at breathing zone height using filter tubes specifically designed for mercury vapor and calibrated low volume pumps. The samples were submitted to SGS Galson and analyzed in accordance with NIOSH Method 6009. SGS Galson is accredited by the American Industrial Hygiene Association (AIHA). Sample locations included the center, the south side, and the northeast corner of the gym. Ventilation or air conditioning equipment were not operating during the sampling, and all doors and windows were closed to avoid outdoor air intrusion.

Mercury generally evaporates slowly from building materials, and the rate of evaporation increases when temperatures rise. Temperatures above 70° F are ideal for mercury vapor monitoring; therefore, sampling was conducted when outdoor temperatures were expected to be greater than 80° F. Indoor temperature measurements were collected during the monitoring period.

There are no federal or Maryland state regulations regarding rubberized gym flooring containing mercury. The HCPSS has adopted widely accepted guidelines from the Minnesota Department of Health and New Jersey Department of Health which indicate that indoor air concentrations below 750 nanograms per cubic meter (ng/m^3) or $0.75 \mu\text{g}/\text{m}^3$ are protective of preschool-aged children, and thus also deemed safe for older children and adults. The Agency for Toxic Substances and Disease Registry (ATSDR) has established $1 \mu\text{g}/\text{m}^3$ as an acceptable concentration for normal occupancy for most sensitive persons regardless of age.

RESULTS

Temperature measurements in the gym were collected using a TSI QTrak 7585 Monitor and ranged from 76.5 to 77.4° F on the day of sampling. These temperatures were considered sufficiently above room temperature for mercury vapor investigation purposes. Mercury vapor was not detected in the samples collected in the gym. Laboratory analytical data is provided in **Attachment A** and summarized in **Table 1** below.

CONCLUSIONS AND RECOMMENDATIONS

Mercury vapor was not detected in the air samples collected and estimated airborne concentrations were below the target concentration (0.75 µg/m³) and the limit of detection for the analytical method (0.31 µg/m³). No further action is recommended.


LIMITATIONS

EFI provided these services consistent with the level and skill ordinarily exercised by members of the profession currently practicing under similar conditions. This report is intended for the sole use of the client.


CLOSING

EFI appreciates this opportunity to provide environmental services for HCPSS. If you require additional information or have questions regarding the contents of this report, please contact either of the undersigned.

Sincerely,
EFI Global, Inc.



Julie Barth, CIH, CSP, LEED Green Associate
Senior Industrial Hygienist-CIH/Project Manager



Danielle Schaefer, CMI
District Environmental Principal

Attachments: Attachment A –Laboratory Analytical Report and Chain of Custody

ATTACHMENT A

**LABORATORY ANALYTICAL REPORT
AND CHAIN OF CUSTODY**



GALSON

**Julie Barth
EFI Global
926 Slash Pine CT
Sykesville, MD 21784**

July 23, 2024

Account# 39857

Login# L631834

Dear Julie Barth:

Enclosed are the analytical results for the samples received by our laboratory on July 17, 2024. All samples on the chain of custody were received in good condition unless otherwise noted. Any additional observations will be noted on the chain of custody.

Please contact client services at (888) 432-5227 if you would like any additional information regarding this report. Thank you for using SGS Galson.

Sincerely,

SGS Galson

A handwritten signature in black ink that reads 'Lisa Swab'. The signature is written in a cursive, flowing style.

**Lisa Swab
Laboratory Director**

Enclosure(s)



Terms and Conditions & General Disclaimers

- This document is issued by the Company under its General Conditions of Service accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.
- Any holder of this document is advised that information contained herein reflects the Company’s findings at the time of its intervention only and within the limits of Client’s instructions, if any. The Company’s sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Analytical Disclaimers

- Unless otherwise noted within the report, all quality control results associated with the samples were within established control limits or did not impact reported results.
- Note: The findings recorded within this report were drawn from analysis of the sample(s) provided to the laboratory by the Client (or a third party acting at the Client’s direction). The laboratory does not have control over the sampling process, including but not limited to the use of field equipment and collection media, as well as the sampling duration, collection volume or any other collection parameter used by the Client. The findings herein constitute no warranty of the sample's representativeness of any sampled environment, and strictly relate to the samples as they were presented to the laboratory. For recommended sampling collection parameters, please refer to the Sampling and Analysis Guide at www.sgsgalson.com.
- Unrounded results are carried through the calculations that yield the final result and the final result is rounded to the number of significant figures appropriate to the accuracy of the analytical method. Please note that results appearing in the columns preceding the final result column may have been rounded and therefore, if carried through the calculations, may not yield an identical final result to the one reported.
- The stated LOQs for each analyte represent the demonstrated LOQ concentrations prior to correction for desorption efficiency (if applicable).
- Unless otherwise noted within the report, results have not been blank corrected for any field blank or method blank data.

Accreditations SGS Galson holds a variety of accreditations and recognitions. Our quality management system conforms with the requirements of ISO/IEC 17025. Where applicable, samples may also be analyzed in accordance with the requirements of ELAP, NELAC, or LELAP under one of the state accrediting bodies listed below. Current Scopes of Accreditation can be viewed at <http://www.sgsgalson.com> in the accreditations section of the "About" page. To determine if the analyte tested falls under our scope of accreditation, please visit our website or call Client Services at (888) 432-5227.

National/International	Accreditation/Recognition	Lab ID#	Program/Sector
AIHA-LAP, LLC - IHLAP, ELLAP, EMLAP	ISO/IEC 17025 and USEPA NLLAP	Lab ID 100324	Industrial Hygiene, Environmental Lead, Environmental Microbiology

State	Accreditation/Recognition	Lab ID#	Program/Sector
New York (NYSDOH)	ELAP and NELAC (TNI)	Lab ID: 11626	Air Analysis, Solid and Hazardous Waste
Louisiana (LDEQ)	LELAP	Lab ID: 04083	Air Analysis, Solid Chemical Materials

Legend

< - Less than	mg - Milligrams	MDL - Method Detection Limit	ppb - Parts per Billion
> - Greater than	ug - Micrograms	NA - Not Applicable	ppm - Parts per Million
l - Liters	m3 - Cubic Meters	NS - Not Specified	ppbv - ppb Volume
LOQ - Limit of Quantitation	kg - Kilograms	ND - Not Detected	ppmv - ppm Volume
ft2 - Square Feet	cm2 - Square Centimeters	in2 - Square Inches	ng - Nanograms



GALSON

LABORATORY ANALYSIS REPORT

6601 Kirkville Road
East Syracuse, NY 13057
(315) 432-5227
FAX: (315) 437-0571
www.sgsgalson.com

Client : EFI Global
Site : OLD CEDAR LANE
Project No. : 048.04546
Date Sampled : 15-JUL-24
Date Received : 17-JUL-24

Account No.: 39857
Login No. : L631834
Date Analyzed : 23-JUL-24
Report ID : 1436960

Mercury, Vapor

<u>Sample ID</u>	<u>Lab ID</u>	<u>Air Vol</u> <u>liter</u>	<u>Total</u> <u>ug</u>	<u>Conc</u> <u>mg/m3</u>
01	L631834-1	96	<0.030	<0.00031
02	L631834-2	96	<0.030	<0.00031
03	L631834-3	96	<0.030	<0.00031

COMMENTS: Please see attached lab footnote report for any applicable footnotes.

Level of Quantitation: 0.030 ug
Analytical Method : mod. NIOSH 6009; CVAA TUBE
Collection Media : 226-17-1A

Submitted by: CAW
Date : 23-JUL-24
Supervisor : JJL

Approved by: JJL



GALSON

LABORATORY FOOTNOTE REPORT

6601 Kirkville Road
East Syracuse, NY 13057
(315) 432-5227
FAX: (315) 437-0571
www.ssggalson.com

Client Name : EFI Global
Site : OLD CEDAR LANE
Project No. : 048.04546

Date Sampled : 15-JUL-24
Date Received: 17-JUL-24
Date Analyzed: 23-JUL-24

Account No.: 39857
Login No. : L631834

L631834 (Report ID: 1436960):

For applicable NYS sampling events, laboratory accreditation through NYSDOH applies only to Lead results.
Reported results reflect elemental analysis of the requested metals. Certain compounds may not be solubilized during digestion, resulting in data that is biased low.
SOPs: im-hgair(31), MT-SOP-20(22)

L631834 (Report ID: 1436960):

Accuracy and mean recovery data presented below is based on a 95% confidence interval (k=2). The estimated accuracy applies to the media, technology, and SOP referenced in this report and does not account for the uncertainty associated with the sampling process. The accuracy is based solely on spike recovery data from internal quality control samples. Where N/A appears below, insufficient data is available to provide statistical accuracy and mean recovery values for the associated analyte.

Parameter	Accuracy	Mean Recovery
Mercury, Vapor	+/-17.7%	102%

277134920335
 Date: 07/17/24
 Shipper: FEDEX
 Initials: OTS
 Prep: UNKNOWN

L631834

42

CHAIN OF CUSTODY

Turn Around Time (TAT) surcharge <input type="checkbox"/> Standard 0% <input type="checkbox"/> 4 Business Days 35% <input type="checkbox"/> 3 Business Days 50% <input type="checkbox"/> 2 Business Days 75% <input type="checkbox"/> Next Day by 6pm 100% <input type="checkbox"/> Next Day by Noon 150% <input type="checkbox"/> Same Day 200%	Client Acct No.: 39857	Report To: Julie Barth	Invoice To: Carolyn Verb
	Original Prep No.: PSY746816	Company Name: EFI Global	Company Name: EFI Global
	Online COC No.: 301114	Address 1: 926 Slash Pine CT	Address 1: 5024 Campbell Blvd
		Address 2:	Address 2: Suite F
		City, State Zip: Sykesville, MD 21784	Company Name: Nottingham, MD 21236
		Phone No.: 443-725-6425	Phone No.: 443-613-6654
		Cell No.:	Email Address: carolyn.verb@efiglobal.com, julie.barth@efiglobal.com
	Email reports to: julie.barth@efiglobal.com	Comments:	P.O. No.:
	Email EDD to: julie.barth@efiglobal.com	Payment info: <input type="checkbox"/> I will call SGS to provide credit card info	<input type="checkbox"/> Card on File (enter the last five digits on the line below)
	Comments:		

Comments: Per prep. Pump cal @ 0.8 0.2 Lpm MER 7/17/24 State Sampled: MD MSHA

Site Name: Old Cedar Lane / 048-04546 Project: 048.04546 Sampled By: Eliot Goodman List description of industry or Processes/Interfaces present in sampling area:

Sample ID (Maximum of 20 Characters)	Date Sampled	Collection Medium	Sample Volume Sample Time Sample Area	Liters Minutes in ² , cm ² , ft ²	Analysis Requested	Method Reference	Internal Notes
01	7.15.24	226-17-1A	100.704 4:30 min 6ym		Mercury, Vapor	mod. NIOSH 6009; CVAA TUBE	
02		226-17-1A			Mercury, Vapor	mod. NIOSH 6009; CVAA TUBE	
03		226-17-1A			Mercury, Vapor	mod. NIOSH 6009; CVAA TUBE	

If the method(s) indicated on the COC are not our routine/preferred method(s), we will substitute our routine/preferred methods. If this is not acceptable, check here to have us contact you.

Chain of Custody	Print Name / Signature	Date	Time	Print Name / Signature	Date	Time
Relinquished By:	Eliot Goodman	7.16.24	3pm	Received By: Olivia T. Silver	7/17/24	1106
Relinquished By:				Received By:		

Samples received after 3pm will be considered as next day's business.

Online COC No.: 301114
 Prep No.: PSY746816
 Account No.: 39857
 Finalized: 07/11/2024 10:44:10

All services are rendered in accordance with the applicable SGS General Conditions of Service accessible via: <http://www.sgs.com/en/Terms-and-Conditions.aspx>



CHAIN OF CUSTODY

Comments:

Sample ID (Maximum of 20 Characters)	Date Sampled	Collection Medium	Sample Volume Sample Time Sample Area	Liters Minutes in ² , cm ² , ft ²	Analysis Requested	Method Reference	Internal Notes
		226-17-1A			Mercury, Vapor	mod. NIOSH 6009; CVAA TUBE	
		37mm UW MCE, 3pc			Mercury, Vapor	mod. NIOSH 6009; CVAA TUBE	
		37mm UW MCE, 3pc			Mercury, Vapor	mod. NIOSH 6009; CVAA TUBE	
		37mm UW MCE, 3pc			Mercury, Vapor	mod. NIOSH 6009; CVAA TUBE	
		37mm UW MCE, 3pc			Mercury, Vapor	mod. NIOSH 6009; CVAA TUBE	

If the method(s) indicated on the COC are not our routine/preferred method(s), we will substitute our routine/preferred methods. If this is not acceptable, check here to have us contact you.

Chain of Custody	Print Name / Signature	Date	Time	Print Name / Signature	Date	Time
Relinquished By:				Received By: <i>Olivia T. Silver</i>	<i>7/17/24</i>	<i>10:11a</i>
Relinquished By:				Received By:		

Samples received after 3pm will be considered as next day's business.

Online COC No. :301114

Prep No. :PSY746816

Account No. :39857

Finalized :07/11/2024 10:44:10

All services are rendered in accordance with the applicable SGS General Conditions of Service accessible via: <http://www.sgs.com/en/Terms-and-Conditions.aspx>