



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Tel/Fax: (800) 220-3675 / (856) 786-0262
<http://www.EMSL.com> / cinnmicrolab@emsl.com

EMSL Order: 372015501

Customer ID: WATE78

Customer PO:

Project ID:

Attention: Eric Messerschmidt
WaterPro, Inc.
5690 French Avenue
Sykesville, MD 21784

Phone: (410) 746-1111

Fax: (410) 551-6053

Collected Date: 09/21/2020 08:40 AM - 09/21/2020 02:00 PM

Received Date: 09/22/2020 09:30 AM

Processed Date: 09/22/2020 02:00 PM

Analyzed Date: 09/29/2020 02:00 PM

Project: HCPB Summer (Howard County)

Legionella Detection - Presumptive ID by CDC Culture Method (EMSL Method M210)

Client Sample ID/Sample Location Lab Sample Number	Sample Type	Volume Submitted (mL)	Volume Filtered (mL)	Method Processed	Identification	Volume Examined (mL)	Limit of Detection (CFU/mL)	Final Results (CFU/mL)
2 - Oakland Mills HS 372015501-0001	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
4 - Cradlerock ES 372015501-0002	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
5 - Oakland Mills MS 372015501-0003	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
7 - Atholton HS 372015501-0004	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
8 - Centennial HS 372015501-0005	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
10 - Wilde Lake HS 372015501-0006	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
11 - Dunloggin MS 372015501-0007	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
12 - Harpers Choice MS 372015501-0008	Non-potable	100	NA	Direct Plate (Acid)	<i>Legionella</i> spp.	0.05	20.00	700.00
13 - Atholton ES 372015501-0009	Non-potable	100	NA	Direct Plate (Acid)	<i>Legionella</i> spp.	0.05	20.00	480.00
15 - Marriotts Ridge HS 372015501-0010	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
16 - MT. Hebron HS 372015501-0011	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
17 - St. John's Lane ES 372015501-0012	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
18 - West Friendship ES 372015501-0013	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
26 - Administration 372015501-0014	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND

Vincent Iuzzolino, M.S., Laboratory Director
or other Approved Signatory

Samples high in non-*Legionella* bacteria may obscure the detection of *Legionella*.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

AIHA-LAP, LLC--EMLAP Accredited #100194, CDC ELITE certified

Initial report from: 10/06/2020 01:02 PM

Printed 10/06/2020 01:03 PM

MIC_CDCISO_0017