



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Tel/Fax: (800) 220-3675 / (856) 786-0262
<http://www.EMSL.com / cinnmicrolab@emsl.com>

EMSL Order: 372015626

Customer ID: WATE78

Customer PO:

Project ID: 2018

Attention: Eric Messerschmidt
WaterPro, Inc.
5690 French Avenue
Sykesville, MD 21784

Phone: (410) 746-1111

Fax: (410) 551-6053

Collected Date: 09/22/2020 08:30 AM - 09/22/2020 01:30 PM

Received Date: 09/23/2020 09:40 AM

Processed Date: 09/23/2020 01:30 PM

Analyzed Date: 09/30/2020 09:00 AM

Project: HCPB Summer (Howard County) (2018)

Legionella Detection - Presumptive ID by CDC Culture Method (EMSL Method M210)

Client Sample ID/Sample Location Lab Sample Number	Sample Type	Volume Submitted (mL)	Volume Filtered (mL)	Method Processed	Identification	Volume Examined (mL)	Limit of Detection (CFU/mL)	Final Results (CFU/mL)
1 - Long Reach HS 372015626-0001	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
6 - Talbott Springs ES 372015626-0002	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
9 - River Hill HS 372015626-0003	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
14 - Clarkville ES 372015626-0004	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
19 - Howard HS Tower 1 372015626-0005	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
20 - Howard HS Tower 2 372015626-0006	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
21 - Howard HS Tower 3 372015626-0007	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
22 - Hammond HS 372015626-0008	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
23 - Reservoir HS 372015626-0009	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
24 - Laurel Woods HS 372015626-0010	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
25 - Firest Ridge ES 372015626-0011	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND

Vincent Iuzzolino, M.S., Laboratory Director
or other Approved Signatory

Samples high in non-*Legionella* bacteria may obscure the detection of *Legionella*.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

AIHA-LAP, LLC--EMLAP Accredited #100194, CDC ELITE certified

Initial report from: 10/05/2020 03:11 PM

Printed 10/05/2020 03:12 PM

MIC_CDCISO_0017