

EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Tel/Fax: (800) 220-3675 / (856) 786-0262
http://www.EMSL.com / cinnmicrolab@emsl.com

EMSL Order: 372017196 Customer ID: WATE78

Customer PO: Project ID:

Attention: Eric Messerschmidt

WaterPro, Inc.

5690 French Avenue Sykesville, MD 21784 Phone: (410) 746-1111 Fax: (410) 795-0329

Collected Date: 10/15/2020 09:00 AM - 10/15/2020 09:15 AM

Received Date: 10/16/2020 11:00 AM Processed Date: 10/16/2020 02:40 PM Analyzed Date: 10/23/2020 09:00 AM

Project: HCPSS Retest (Howard County)

Legionella Detection - Presumptive ID by CDC Culture Method (EMSL Method M210)

Client Sample ID/Sample Location Lab Sample Number	Sample Type	Volume Submitted (mL)	Volume Filtered (mL)	Method Processed	Identification	Volume Examined (mL)	Limit of Detection (CFU/mL)	Final Results (CFU/mL)
1 - Atholton ES 372017196-0001	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
2 - Harpers Choice MS 372017196-0002	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND

Vincent luzzolino, M.S., Laboratory Director or other Approved Signatory

Samples high in non-Legionella bacteria may obscure the detection of Legionella.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

AIHA-LAP, LLC--EMLAP Accredited #100194, CDC ELITE certified

Initial report from: 10/23/2020 12:45 PM

Printed 10/23/2020 12:45 PM Page 1 of 1